



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
31	7.8				Y
30	7.7				Y
29	7.8				Y
28	7.9				Y
27	7.7				Y
26	7.6				Y
25	7.7				Y
24	7.9				Y
23	7.9				Y
22	7.9				Y
21	7.8				Y
20	7.7				Y
19	7.9				Y
18	8.0				Y
17	7.9				Y
16	7.6				Y
15	7.8				Y
14	7.7				Y
13	7.9				Y
12	7.8				Y
11	7.4				Y
10	8.0				Y
9	8.1				Y
8	8.0				Y
7	7.5				Y
6	7.6				Y
5	7.8				Y
4	7.9				Y
3	8.0				Y
2	8.1				Y
1	8.2				Y

<<Have minimums been met for this day?

**ENTRY POINT**  
**A**  
**PWS ID 4100886**  
**CLOVERDALE WATER DISTRICT**

Sample period: March/2022  
 Month/Year

Number of excursions\* during this month: 2  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 2  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)  
 Is system in compliance? Y/N

Reference \_\_\_\_\_

Minimum Water Quality Parameters as set by State:  
 pH 7.2

Print Name: Larry Chitwood  
 Signature: \_\_\_\_\_  
 Date: 4-7-2022

(No = N = Excursion) Total N's 2

Send to OHD within 10 days after end of sampling period  
 Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381