



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31	7.74				Y
30	7.78				Y
29	7.99				Y
28	8.03				Y
27	8.21				Y
26	8.33				Y
25	8.46				Y
24	8.2				Y
23	7.66				Y
22	7.63				Y
21	7.93				Y
20	7.77				Y
19	7.71				Y
18	7.69				Y
17	7.67				Y
16	7.45				Y
15	7.72				Y
14	7.71				Y
13	7.83				Y
12	7.94				Y
11	7.52				Y
10	7.44				Y
9	7.44				Y
8	7.63				Y
7	7.64				Y
6	7.68				Y
5	7.72				Y
4	7.79				Y
3	7.83				Y
2	8.13				Y
1	8.59				Y

<<Have minimums been met for this day?

ENTRY POINT

A

PWS ID 4100886

CLOVERDALE WATER DISTRICT

Sample period: May/2022
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y / N

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Chitwood

Signature: [Signature]

Date: 06/08/2022

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381