



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31					Y
30	7.58				Y
29	7.62				Y
28	7.77				Y
27	7.74				Y
26	7.67				Y
25	7.99				Y
24	7.80				Y
23	7.33				Y
22	7.20				Y
21	7.54				Y
20	7.79				Y
19	7.74				Y
18	7.77				Y
17	7.79				Y
16	7.78				Y
15	7.66				Y
14	7.66				Y
13	7.57				Y
12	7.45				Y
11	7.88				Y
10	7.96				Y
9	7.78				Y
8	7.75				Y
7	7.87				Y
6	7.66				Y
5	7.68				Y
4	7.85				Y
3	7.75				Y
2	7.82				Y
1	7.92				Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: June 7 2022
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y/N

Reference _____

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Chitwood

Signature: [Signature]

Date: 7/5/2022

(No = N = Excursion) Total N's 0