



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31	8.03				Y
30	8.43				Y
29	7.55				Y
28	7.33				Y
27	7.41				Y
26	7.55				Y
25	7.5				Y
24	7.46				Y
23	7.48				Y
22	7.57				Y
21	7.79				Y
20	7.83				Y
19	7.87				Y
18	7.3				Y
17	7.43				Y
16	7.55				Y
15	7.21				Y
14	7.88				Y
13	7.81				Y
12	7.25				Y
11	7.92				Y
10	8.16				Y
9	8.15				Y
8	7.83				Y
7	7.44				Y
6	7.4				Y
5	7.35				Y
4	7.4				Y
3	7.47				Y
2	7.62				Y
1	7.66				Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: AUGUST / 2022
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y / N

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Ch. Wood
 Signature: [Signature]
 Date: 9-8-2022

(No = N = Excursion) Total N's 0