



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
31	7.21				Y
30	7.23				Y
29	7.25				Y
28	7.27				Y
27	7.54				Y
26	7.59				Y
25	7.44				Y
24	7.29				Y
23	7.27				Y
22	7.44				Y
21	7.29				Y
20	7.5				Y
19	7.48				Y
18	7.43				Y
17	7.5				Y
16	7.33				Y
15	7.29				Y
14	7.83				Y
13	7.79				Y
12	7.22				Y
11	7.33				Y
10	7.44	19			Y
9	7.7				Y
8	7.84				Y
7	7.88				Y
6	7.59				Y
5	7.83				Y
4	7.69				Y
3	7.71				Y
2	7.8				Y
1	7.84				Y

<<Have minimums been met for this day?

**ENTRY POINT**  
**A**  
**PWS ID 4100886**  
**CLOVERDALE WATER DISTRICT**

Sample period: October/2022  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y / N

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Chitwood  
 Signature: [Signature]  
 Date: 11/8/2022

(No = N = Excursion) Total N's 0