



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
31					Y
30	8.18				Y
29	8.11				Y
28	7.85				Y
27	7.83				Y
26	8.25				Y
25	8.32				Y
24	7.88				Y
23	7.54				Y
22	7.51				Y
21	7.39				Y
20	7.69				Y
19	7.56				Y
18	7.69				Y
17	7.78				Y
16	7.92				Y
15	8.19				Y
14	7.78				Y
13	7.71				Y
12	7.8				Y
11	7.97				Y
10	7.7				Y
9	7.68				Y
8	7.78				Y
7	7.83				Y
6	7.73				Y
5	7.54				Y
4	7.41				Y
3	7.33				Y
2	7.29				Y
1	7.23				Y

<<Have minimums been met for this day?

**ENTRY POINT**  
**A**  
**PWS ID 4100886**  
**CLOVERDALE WATER DISTRICT**

Sample period: November/2022  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)  
 Is system in compliance? Y / N

Reference \_\_\_\_\_

Minimum Water Quality Parameters as set by State:  
 pH 7.2

Print Name: Larry Chitwood  
 Signature: \_\_\_\_\_  
 Date: 12/7/2022

(No = N = Excursion) Total N's 0