



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31	7.8				Y
30	7.8				Y
29	7.6				Y
28	7.7				Y
27	7.9				Y
26	8				Y
25	8.2				Y
24	7.8				Y
23	7.6				Y
22	7.6				Y
21	7.9				Y
20	8.3				Y
19	7.7				Y
18	7.4				Y
17	7.4				Y
16	7.3				Y
15	7.3				Y
14	7.3				Y
13	7.3				Y
12	7.6				Y
11	7.2				Y
10	7.3				Y
9	7.3				Y
8	7.3				Y
7	7.8				Y
6	7.5				Y
5	8.1				Y
4	8.5				Y
3	8.4				Y
2	8.2				Y
1	8.2				Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: December/2022
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y/N

Reference

Minimum Water Quality Parameters as set by State:
 pH 7.2

Print Name: Larry Chitwood
 Signature: [Signature]
 Date: 1-5-2023

(No = N = Excursion) Total N's 0