



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31	7.8				Y
30	7.9				Y
29	7.9				Y
28	8				Y
27	8.2				Y
26	8.3				Y
25	8.9				Y
24	8.9				Y
23	9.2				Y
22	8.4				Y
21	8.3				Y
20	7.8				Y
19	7.6				Y
18	7.6				Y
17	7.4				Y
16	7.8				Y
15	7.7				Y
14	7.6				Y
13	7.5				Y
12	7.4				Y
11	7.4				Y
10	7.3				Y
9	7.8				Y
8	7.5				Y
7	7.7				Y
6	7.8				Y
5	7.5				Y
4	7.5				Y
3	7.6				Y
2	7.7				Y
1	7.6				Y

<<Have minimums been met for this day?

ENTRY POINT

A

PWS ID 4100886

CLOVERDALE WATER DISTRICT

Sample period: January/2023
 Month/Year

Number of excursions* during this month: 2
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 2
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y/N

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Chitwood
 Signature: [Signature]
 Date: 2/1/2023

(No = N = Excursion) Total N's 2