



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31					
30					
29					
28	7.7				Y
27	7.7				Y
26	7.7				Y
25	7.7				Y
24	7.7				Y
23	7.6				Y
22	7.5				Y
21	7.4				Y
20	7.8				Y
19	7.6				Y
18	7.5				Y
17	7.6				Y
16	8.2				Y
15	8.2				Y
14	7.8				Y
13	7.3				Y
12	7.5				Y
11	7.5				Y
10	7.5				Y
9	7.6				Y
8	7.6				Y
7	7.6				Y
6	7.7				Y
5	7.7				Y
4	7.7				Y
3	7.7				Y
2	7.7				Y
1	7.8				Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: February / 2023
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y / N

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Lynn Whitwood
 Signature: _____
 Date: 3/8/2023

(No = N = Excursion) Total N's 0