



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31	7.57				Y
30	7.55				Y
29	7.39				Y
28	7.4				Y
27	7.4				Y
26	7.22				Y
25	7.34				Y
24	7.36				Y
23	7.38				Y
22	7.34				Y
21	7.38				Y
20	7.36				Y
19	7.4				Y
18	7.44				Y
17	7.38				Y
16	7.36				Y
15	7.34				Y
14	7.4				Y
13	7.51				Y
12	7.53				Y
11	7.47				Y
10	7.48				Y
9	7.51				Y
8	7.64				Y
7	7.66				Y
6	7.38				Y
5	7.92				Y
4	8.3				Y
3	8.16				Y
2	7.9				Y
1	7.84				Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: April / 2023
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Is system in compliance? Y / N

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Critwood
 Signature: [Signature]
 Date: 5/5/2023

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period
 Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381