



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31	8.1				Y
30	8.16				Y
29	8.15				Y
28	8.23				Y
27	8.04				Y
26	8.09				Y
25	8.04				Y
24	7.99				Y
23	8.01				Y
22	7.98				Y
21	8.0				Y
20	8.02				Y
19	8.05				Y
18	7.96				Y
17	7.7				Y
16	7.63				Y
15	7.28				Y
14	7.28				Y
13	7.27				Y
12	7.3				Y
11	7.65				Y
10	7.66				Y
9	7.62				Y
8	7.64				Y
7	7.66				Y
6	7.69				Y
5	7.7				Y
4	7.61				Y
3	7.5				Y
2	7.54				Y
1	7.6				Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: May / 2023
 Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y N

Reference

Minimum Water Quality Parameters as set by State:
 pH 7.2

Print Name: Larry Chitwood
 Signature: [Signature]
 Date: 6/6/2023

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period
 Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381