



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
31					
30	7.8				Y
29	7.6				Y
28	7.7				Y
27	7.8				Y
26	7.8				Y
25	7.7				Y
24	7.6				Y
23	7.6				Y
22	7.6				Y
21	7.6				Y
20	7.6				Y
19	7.7				Y
18	7.7				Y
17	7.7				Y
16	7.7				Y
15	7.7				Y
14	7.7				Y
13	7.7				Y
12	7.7				Y
11	7.6				Y
10	7.6				Y
9	7.6				Y
8	7.4				Y
7	7.5				Y
6	7.5				Y
5	7.6				Y
4	7.6				Y
3	7.7				Y
2	7.8				Y
1	7.8				Y

<<Have minimums been met for this day?

**ENTRY POINT**  
**A**  
**PWS ID 4100886**  
**CLOVERDALE WATER DISTRICT**

Sample period: JUNE / 2023  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)  
 Is system in compliance? Y / N

—Reference—

Minimum Water Quality Parameters as set by State:  
 pH 7.2

Print Name: Larry Chitwood  
 Signature: [Signature]  
 Date: 7/8/2023

(No = N = Excursion) Total N's 0