



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31	7.77				Y
30	7.72				Y
29	7.94				Y
28	7.73				Y
27	7.67				Y
26	7.65				Y
25	7.58				Y
24	7.47				Y
23	7.62				Y
22	7.48				Y
21	7.56				Y
20	7.58				Y
19	7.61				Y
18	7.68				Y
17	7.7				Y
16	7.71				Y
15	7.81				Y
14	7.77				Y
13	7.75				Y
12	7.83				Y
11	8.01				Y
10	7.96				Y
9	8.1				Y
8	8.08				Y
7	8.4				Y
6	8.36				Y
5	8.2				Y
4	8.12				Y
3	8.15				Y
2	8.12				Y
1	7.88				Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: 5/17/2023
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y N

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Chitwood
 Signature: [Signature]
 Date: 8-9-23

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period
 Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381