



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31					
30	7.8				Y
29	7.9				Y
28	7.9				Y
27	7.9				Y
26	7.8				Y
25	7.8				Y
24	7.8				Y
23	7.8				Y
22	7.6				Y
21	7.6				Y
20	7.7				Y
19	7.6				Y
18	7.5				Y
17	7.7				Y
16	7.6				Y
15	7.5				Y
14	7.4				Y
13	7.6				Y
12	7.7				Y
11	7.6				Y
10	7.6				Y
9	7.6				Y
8	7.6				Y
7	7.7				Y
6	7.7				Y
5	7.8				Y
4	7.7				Y
3	7.6				Y
2	7.7				Y
1	7.83				Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: September 2023
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? **Y / N**

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Chitwood
 Signature: [Signature]
 Date: 10/6/2023

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period
 Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381