



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31	7.66				Y
30	7.61				Y
29	7.64				Y
28	7.6				Y
27	7.68				Y
26	7.71				Y
25	7.65				Y
24	7.63				Y
23	7.59				Y
22	7.61				Y
21	7.63				Y
20	7.59				Y
19	7.54				Y
18	7.53				Y
17	7.57				Y
16	7.53				Y
15	7.57				Y
14	7.53				Y
13	7.59				Y
12	7.54				Y
11	7.55				Y
10	7.59				Y
9	7.59				Y
8	7.62				Y
7	7.68				Y
6	7.7				Y
5	7.71				Y
4	7.7				Y
3	7.72				Y
2	7.71				Y
1	7.78				Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: OCTOBER / 2023
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y / N

Reference

Minimum Water Quality Parameters as set by State:
 pH 7.2

Print Name: LARRY CHITWOOD
 Signature: [Signature]
 Date: 11-6-2023

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period
 Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381