



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31	7.5	68			Y
30	7.6	68			Y
29	7.6	68			Y
28	7.8	62			Y
27	7.9	68			Y
26	7.6	68			Y
25	7.8	68			Y
24	7.9	62			Y
23	7.9	62			Y
22	8	62			Y
21	8	62			Y
20	7.5	69			Y
19	7.5	68			Y
18	7.7	69			Y
17	7.8	69			Y
16	7.8	69			Y
15	8	68			Y
14	8.1	68			Y
13	7.4	68			Y
12	7.5	55			Y
11	7.5	69			Y
10	7.4	68			Y
9	8	55			Y
8	8	55			Y
7	8	55			Y
6	8	68			Y
5	8.4	68			Y
4	8	68			Y
3	8.4	68			Y
2	8.4	68			Y
1	7.6	68			Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: JANUARY / 2024
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? **Y / N**

Reference

Minimum Water Quality Parameters as set by State:
 pH 7.2

Print Name: Larry Chitwood
 Signature: [Signature]
 Date: 2-6-2024

(No = N = Excursion) Total N's 0