



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31					
30					
29	7.7	55			Y
28	7.9	55			Y
27	7.9	55			Y
26	7.85	62			Y
25	7.8	62			Y
24	7.85	62			Y
23	7.85	62			Y
22	7.8	62			Y
21	7.8	62			Y
20	7.7	62			Y
19	7.75	62			Y
18	7.8	62			Y
17	7.8	62			Y
16	7.7	55			Y
15	7.8	55			Y
14	7.6	55			Y
13	7.5	48			Y
12	7.5	48			Y
11	7.6	68			Y
10	7.6	68			Y
9	7.45	55			Y
8	7.4	55			Y
7	7.4	55			Y
6	7.4	48			Y
5	7.4	55			Y
4	7.5	68			Y
3	7.4	68			Y
2	7.4	68			Y
1	7.5	68			Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: February / 2024
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y/N

Reference

Minimum Water Quality Parameters as set by State:
 pH 7.2

Print Name: Larry Chitwood
 Signature: [Signature]
 Date: 3-6-2024

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period
 Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381