



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

| Day | pH  | Alk  | Phos | Sili | Y/N |
|-----|-----|------|------|------|-----|
| 31  | 7.7 | 54.8 |      |      | Y   |
| 30  | 7.4 | 54.8 |      |      | Y   |
| 29  | 8.2 | 54.8 |      |      | Y   |
| 28  | 8.2 | 54.8 |      |      | Y   |
| 27  | 8.1 | 54.8 |      |      | Y   |
| 26  | 8.2 | 61.6 |      |      | Y   |
| 25  | 8.2 | 61.6 |      |      | Y   |
| 24  | 8.1 | 61.6 |      |      | Y   |
| 23  | 8.2 | 61.6 |      |      | Y   |
| 22  | 8   | 54.8 |      |      | Y   |
| 21  | 8   | 54.8 |      |      | Y   |
| 20  | 8   | 55   |      |      | Y   |
| 19  | 8   | 55   |      |      | Y   |
| 18  | 8   | 62   |      |      | Y   |
| 17  | 8.3 | 62   |      |      | Y   |
| 16  | 8.4 | 62   |      |      | Y   |
| 15  | 7.9 | 62   |      |      | Y   |
| 14  | 7.9 | 62   |      |      | Y   |
| 13  | 8   | 62   |      |      | Y   |
| 12  | 8.2 | 62   |      |      | Y   |
| 11  | 8   | 62   |      |      | Y   |
| 10  | 8   | 62   |      |      | Y   |
| 9   | 7.8 | 55   |      |      | Y   |
| 8   | 7.8 | 55   |      |      | Y   |
| 7   | 7.7 | 55   |      |      | Y   |
| 6   | 7.4 | 55   |      |      | Y   |
| 5   | 7.4 | 55   |      |      | Y   |
| 4   | 7.8 | 55   |      |      | Y   |
| 3   | 8   | 55   |      |      | Y   |
| 2   | 7.8 | 55   |      |      | Y   |
| 1   | 7.7 | 55   |      |      | Y   |

<<Have minimums been met for this day?

**ENTRY POINT**  
**A**  
**PWS ID 4100886**  
**CLOVERDALE WATER DISTRICT**

Sample period: March 12024  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)  
 Is system in compliance? (Y) N

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Chitwood  
 Signature: [Signature]  
 Date: 4-4-2024

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period  
 Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381