



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
31	7.6	120			Y
30	7.3	72			
29	7.6	82			
28	7.8	100			
27	7.9	98			
26	7.7	92			
25	7.7	92			
24	7.6	90			
23	7.6	90			
22	7.9	100			
21	7.8	80			
20	7.7	80			
19	7.8	80			
18	7.8	78			
17	7.8	78			
16	7.7	80			
15	7.5	80			
14	7.5	72			
13	7.5	70			
12	7.4	70			
11	7.5	90			
10	7.5	80			
9	7.5	80			
8	8	80			
7	8.2	100			
6	8.4	108			
5	8.3	100			
4	8.3	62			
3	8.3	100			
2	8.4	100			
1	8.2	110			Y

<<Have minimums been met for this day?

**ENTRY POINT**

**A**

**PWS ID 4100886**

**CLOVERDALE WATER DISTRICT**

Sample period: May / 2024  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)  
 Is system in compliance? Y / N

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Chitwood

Signature: [Signature]

Date: 6-6-2024

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period  
 Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381