



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31					7
30	7.9	95			1
29	7.9	100			
28	7.8	98			
27	8	90			
26	7.9	93			
25	7.6	96			
24	7.6	100			
23	8	90			
22	7.8	99			
21	8	98			
20	7.6	100			
19	7.4	110			
18	7.6	100			
17	7.6	100			
16	7.4	95			
15	7.6	80			
14	7.5	112			
13	7.4	100			
12	7.6	100			
11	8	96			
10	8.2	100			
9	8	100			
8	7.9	110			
7	7.7	98			
6	7.5	96			
5	7.7	92			
4	7.8	92			
3	7.8	96			
2	7.8	100			
1	7.7	100			✓

<<Have minimums been met for this day?

ENTRY POINT
A

PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: JUNE / 2024
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y / N

Reference _____

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Larry Chitwood

Signature: [Signature]

Date: 7-2-2024

(No = N = Excursion) Total N's 0