



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31	7.5	90			Y
30	7.5	82			
29	7.4	83			
28	7.4	82			
27	7.7	82			
26	7.7	82			
25	7.8	82			
24	7.9	82			
23	8.2	87			
22	8.0	80			
21	8.1	95			
20	8.0	100			
19	8.0	95			
18	7.9	86			
17	7.9	82			
16	7.5	80			
15	7.3	82			
14	7.3	82			
13	7.2	75			
12	7.5	80			
11	8.0	95			
10	8.0	97			
9	8.0	85			
8	8.0	82			
7	8.0	80			
6	7.8	72			
5	7.9	68			
4	7.9	74			
3	8.0	94			
2	8.1	88			
1	8.0	96			

<<Have minimums been met for this day?

ENTRY POINT

A

PWS ID 4100886

CLOVERDALE WATER DISTRICT

Sample period: JULY/2024
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y N

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: LARRY CHITWOOD

Signature: [Signature]

Date: 8-2-2024

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381