



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31	7.8	82			Y
30	7.9	85			Y
29	7.5	90			Y
28	7.9	95			Y
27	7.8	98			Y
26	7.6	92			Y
25	7.6	92			Y
24	8.0	84			Y
23	7.9	100			Y
22	7.9	92			Y
21	8.0	92			Y
20	7.7	90			Y
19	7.8	84			Y
18	7.8	88			Y
17	7.8	104			Y
16	7.6	86			Y
15	7.8	82			Y
14	7.5	78			Y
13	7.5	80			Y
12	7.9	83			Y
11	8.0	100			Y
10	7.8	82			Y
9	7.5	82			Y
8	7.5	83			Y
7	7.5	80			Y
6	7.9	78			Y
5	7.6	95			Y
4	7.6	76			Y
3	7.5	75			Y
2	7.5	79			Y
1	7.4	80			Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: 8 / 2024
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 5 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y/N

Reference

Minimum Water Quality Parameters as set by State:
 pH 7.2

(No = N = Excursion) Total N's 0

Print Name: Larry Chitwood
 Signature: [Signature]
 Date: 9-6-2024

Send to OHD within 10 days after end of sampling period
 Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381