



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31					Y
30	7.4	80			Y
29	7.6	80			Y
28	7.5	90			Y
27	7.8	82			Y
26	7.8	100			Y
25	8.2	80			Y
24	8.0	100			Y
23	8.0	98			Y
22	7.9	82			Y
21	7.5	90			Y
20	7.5	100			Y
19	7.6	90			Y
18	7.6	80			Y
17	7.6	80			Y
16	7.5	82			Y
15	7.9	100			Y
14	7.9	80			Y
13	8.0	82			Y
12	7.9	88			Y
11	8.1	82			Y
10	8.0	82			Y
9	7.8	84			Y
8	7.5	82			Y
7	7.6	80			Y
6	7.5	80			Y
5	7.8	75			Y
4	7.8	85			Y
3	7.9	75			Y
2	7.8	85			Y
1	7.8	85			Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: September 2024
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y/N

Reference

Minimum Water Quality Parameters as set by State:
 pH 7.2

Print Name: Larry Chitwood
 Signature: [Signature]
 Date: 10-7-2024

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period
 Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381