



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
31	7.4	78			Y
30	7.8	90			Y
29	7.9	82			Y
28	7.9	82			Y
27	7.8	100			Y
26	7.7	90			Y
25	7.8	98			Y
24	7.9	84			Y
23	7.9	84			Y
22	7.9	82			Y
21	7.9	80			Y
20	7.9	80			Y
19	7.9	85			Y
18	7.9	95			Y
17	7.5	100			Y
16	7.5	80			Y
15	7.9	88			Y
14	7.8	88			Y
13	7.5	75			Y
12	7.7	80			Y
11	7.9	80			Y
10	7.5	80			Y
9	8.0	90			Y
8	8.0	84			Y
7	7.6	86			Y
6	7.7	80			Y
5	7.5	84			Y
4	7.5	82			Y
3	7.5	82			Y
2	7.5	84			Y
1	7.5	82			Y

<<Have minimums been met for this day?

**ENTRY POINT**  
**A**  
**PWS ID 4100886**  
**CLOVERDALE WATER DISTRICT**

Sample period: October 2024  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )  
 Is system in compliance? (Y) N

Reference

Minimum Water Quality Parameters as set by State:  
 pH 7.2

Print Name: Larry Chitwood  
 Signature: [Signature]  
 Date: 11-5-2024

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period  
 Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381