

Day	pH	Alk	Phos	Other	Y/N
1	7.4	65			Y
2	7.5	70			Y
3	7.5	72			Y
4	7.6	90			Y
5	7.6	80			Y
6	7.6	100			Y
7	7.5	90			Y
8	7.6	90			Y
9	7.6	80			Y
10	7.6	82			Y
11	7.6	80			Y
12	7.5	90			Y
13	7.9	82			Y
14	7.7	90			Y
15	7.7	88			Y
16	7.6	76			Y
17	7.6	80			Y
18	7.6	76			Y
19	7.5	80			Y
20	7.7	90			Y
21	7.9	95			Y
22	7.6	85			Y
23	7.6	90			Y
24	7.6	98			Y
25	7.7	95			Y
26	7.7	95			Y
27	7.6	90			Y
28	7.6	95			Y
29	7.6	80			Y
30	7.7	100			Y
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: November 2024  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	7.2	
Alk	20	(Alkalinity)
PO4	N/A	(Orthophosphate)
Other	N/A	(_____)

Print Name: Alicia Olson

Signature: [Signature]

Date: 12/1/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0