

Day	pH	Alk	Phos	Other	Y/N
1	7.7	90			Y
2	7.6	95			Y
3	7.4	95			Y
4	7.4	95			Y
5	7.4	90			Y
6	7.7	82			Y
7	7.3	95			Y
8	7.4	100			Y
9	7.4	98			Y
10	7.5	92			Y
11	7.7	80			Y
12	7.5	80			Y
13	7.6	85			Y
14	7.5	100			Y
15	7.4	100			Y
16	7.4	98			Y
17	7.5	82			Y
18	7.5	88			Y
19	7.5	88			Y
20	7.6	98			Y
21	7.4	98			Y
22	7.5	98			Y
23	7.4	95			Y
24	7.5	88			Y
25	7.6	88			Y
26	7.5	81			Y
27	7.7	82			Y
28	7.4	95			Y
29	7.4	88			Y
30	7.4	95			Y
31	7.4	80			Y
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: Dec. 2024
 Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	20	(Alkalinity)
PO4	N/A	(Orthophosphate)
Other	N/A	(_____)

Print Name: Alicia Olson

Signature: [Signature]

Date: 1/1/25

Send to DWP within 10 days after end of sampling period