

Day	pH	Alk	Phos	Other	Y/N
1	7.4	82			Y
2	7.4	98			Y
3	7.4	90			Y
4	7.3	98			Y
5	7.3	82			Y
6	7.4	100			Y
7	7.4	90			Y
8	7.5	95			Y
9	7.5	98			Y
10	7.5	82			Y
11	7.5	82			Y
12	7.5	82			Y
13	7.6	92			Y
14	7.5	80			Y
15	7.6	85			Y
16	7.5	84			Y
17	7.6	82			Y
18	7.5	86			Y
19	7.6	105			Y
20	7.5	98			Y
21	7.4	90			Y
22	7.3	70			Y
23	7.4	82			Y
24	7.3	70			Y
25	7.2	90			Y
26	7.5	90			Y
27	8.4	100			Y
28	8.4	100			Y
29	8.4	108			Y
30	8.4	120			Y
31	8.4	108			Y
					0

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: January 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.2</u>	
Alk	<u>20</u>	(Alkalinity)
PO4	<u>N/A</u>	(Orthophosphate)
Other	<u>N/A</u>	(_____)

Print Name: Alicia Olson

Signature: [Signature]

Date: 2/4/2025

Send to DWP within 10 days after end of sampling period