

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.4	119			N
2	8.4	105			N
3	8.2	100			N
4	7.9	100			N
5	8.0	100			N
6	8.0	100			N
7	7.9	97			N
8	7.9	100			N
9	7.6	110			N
10	7.6	100			N
11	7.4	105			N
12	7.6	100			N
13	7.6	100			N
14	7.6	90			N
15	7.4	95			N
16	7.7	110			N
17	7.7	110			N
18	8.0	105			N
19	8.2	110			N
20	8.3	110			N
21	8.3	98			N
22	8.2	100			N
23	8.1	115			N
24	8.0	105			N
25	8.0	100			N
26	8.0	92			N
27	7.4	80			N
28	8.0	98			N
29					
30					
31					

<<Have  
minimums  
been met for  
this day?

### ENTRY POINT

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: February 2025

Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )

For OHA use only

#### Minimum Water Quality Parameters as set by

pH	7.2	
Alk	20	(Alkalinity)
PO4	N/A	(Orthophosphate)
Other	N/A	(_____)

Print Name: Alicia Olson

Signature: [Signature]

Date: 3/3/2025

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's 0