

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6	80			Y
2	7.6	84			Y
3	7.7	90			Y
4	7.8	110			Y
5	7.8	110			Y
6	7.6	90			Y
7	7.6	92			Y
8	7.6	80			Y
9	7.9	92			Y
10	7.9	94			Y
11	8.0	90			Y
12	8.2	100			Y
13	8.0	100			Y
14	8.0	84			Y
15	8.2	84			Y
16	8.1	82			Y
17	8.0	84			Y
18	8.0	110			Y
19	8.4	110			Y
20	8.4	112			Y
21	8.2	92			Y
22	8.1	91			Y
23	8.3	92			Y
24	8.4	100			Y
25	8.2	105			Y
26	8.0	105			Y
27	7.9	118			Y
28	8.0	82			Y
29	7.8	100			Y
30	7.9	96			Y
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: April 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.2</u>	
Alk	<u>20</u>	(Alkalinity)
PO4	<u>N/A</u>	(Orthophosphate)
Other	<u>N/A</u>	(_____)

Print Name: Alicia Olson

Signature: [Signature]

Date: 5/6/25

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0