

Day	pH	Alk	Phos	Other	Y/N
1	8.0	82			Y
2	7.8	98			Y
3	7.6	100			Y
4	7.8	110			Y
5	7.9	100			Y
6	7.8	80			Y
7	7.6	81			Y
8	7.8	82			Y
9	7.8	105			Y
10	7.6	110			Y
11	7.8	100			Y
12	7.7	100			Y
13	7.6	92			Y
14	7.7	94			Y
15	7.6	92			Y
16	7.7	100			Y
17	7.6	105			Y
18	7.9	95			Y
19	7.9	96			Y
20	8.1	96			Y
21	8.1	97			Y
22	8.0	100			Y
23	8.0	105			Y
24	8.0	90			Y
25	7.9	98			Y
26	8.0	96			Y
27	8.0	98			Y
28	7.9	104			Y
29	8.0	96			Y
30	7.6	84			Y
31	7.8	100			Y

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: May 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	20	(Alkalinity)
PO4	N/A	(Orthophosphate)
Other	N/A	(_____)

Print Name: Alicia Olson

Signature: [Signature]

Date: 6/7/2025

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0