

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.9	98			Y
2	7.9	82			Y
3	7.9	96			Y
4	7.9	94			Y
5	7.9	89			Y
6	7.8	92			Y
7	8.0	93			Y
8	8.0	92			Y
9	8.0	94			Y
10	8.0	87			Y
11	8.0	84			Y
12	8.0	86			Y
13	8.0	90			Y
14	8.0	90			Y
15	8.0	94			Y
16	8.0	89			Y
17	8.1	85			Y
18	8.0	87			Y
19	8.0	86			Y
20	8.0	82			Y
21	8.0	84			Y
22	8.0	84			Y
23	8.0	84			Y
24	8.0	83			Y
25	8.0	82			Y
26	8.0	84			Y
27	8.0	83			Y
28	8.0	94			Y
29	8.0	82			Y
30	8.0	86			Y
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: June 2025

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2

Alk 20 (Alkalinity)

PO4 N/A (Orthophosphate)

Other N/A ()

Print Name: Alicia Olson

Signature: [Signature]

Date: 7/7/2025

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0