

Day	pH	Alk	Phos	Other	Y/N
1	8.0	100			Y
2	8.0	98			Y
3	8.0	98			Y
4	8.1	100			Y
5	8.0	96			Y
6	8.0	98			Y
7	8.2	82			Y
8	8.0	87			Y
9	8.0	86			Y
10	8.1	90			Y
11	8.0	99			Y
12	8.0	86			Y
13	8.0	90			Y
14	8.0	82			Y
15	8.0	84			Y
16	8.0	82			Y
17	8.0	82			Y
18	8.0	94			Y
19	8.0	96			Y
20	8.0	96			Y
21	8.1	95			Y
22	8.1	97			Y
23	8.0	92			Y
24	8.0	94			Y
25	8.0	104			Y
26	8.0	80			Y
27	8.0	80			Y
28	8.0	84			Y
29	8.0	100			Y
30	8.1	80			Y
31	8.0	86			Y

<<Have  
minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: July 2025

Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH	7.2	
Alk	20	(Alkalinity)
PO4	N/A	(Orthophosphate)
Other	N/A	(_____)

Print Name: Alicia Olson

Signature: [Signature]

Date: 8/5/25

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's 0