

Day	pH	Alk	Phos	Other	Y/N
1	8.0	100			Y
2	8.0	96			Y
3	8.0	82			Y
4	8.0	84			Y
5	8.0	81			Y
6	8.0	85			Y
7	8.2	97			Y
8	8.0	90			Y
9	8.0	102			Y
10	8.0	110			Y
11	8.4	83			Y
12	8.4	107			Y
13	8.3	103			Y
14	7.8	107			Y
15	7.8	110			Y
16	7.8	80			Y
17	7.8	80			Y
18	7.8	83			Y
19	7.5	82			Y
20	7.5	82			Y
21	8.0	90			Y
22	8.0	120			Y
23	8.2	90			Y
24	8.0	95			Y
25	8.3	100			Y
26	8.0	81			Y
27	8.0	80			Y
28	8.1	80			Y
29	7.4	75			Y
30	7.5	70			Y
31	7.5	75			Y
					0

(No = N = Excursion) Total N's

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: August 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality
Parameters as set by

pH	7.2	
Alk	20	(Alkalinity)
PO4	N/A	(Orthophosphate)
Other	N/A	()

Print Name: Alicia Olso

Signature: [Signature]

Date: 9/1/2025

Send to DWP within 10 days after end of
sampling period