

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.0	98			Y
2	8.3	98			Y
3	8.3	96			Y
4	7.7	84			Y
5	8.0	95			Y
6	8.0	80			Y
7	7.6	80			Y
8	7.6	82			Y
9	7.6	82			Y
10	8.0	86			Y
11	8.1	82			Y
12	8.2	80			Y
13	8.1	78			Y
14	8.2	100			Y
15	8.1	84			Y
16	8.2	87			Y
17	8.2	96			Y
18	8.3	83			Y
19	8.2	80			Y
20	8.1	80			Y
21	7.4	76			Y
22	7.5	82			Y
23	7.5	86			Y
24	7.6	81			Y
25	8.0	97			Y
26	8.0	75			Y
27	8.0	80			Y
28	8.0	90			Y
29	8.1	87			Y
30	8.2	100			Y
31					

(No = N = Excursion) Total N's

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: September 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	20	(Alkalinity)
PO4	N/A	(Orthophosphate)
Other	N/A	()

Print Name: Alicia Olson

Signature: [Signature]

Date: 10/1/2025

Send to DWP within 10 days after end of
sampling period