

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

| Day | pH  | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1   | 8.1 | 93  |      |       | Y   |
| 2   | 8.0 | 84  |      |       | Y   |
| 3   | 8.0 | 100 |      |       | Y   |
| 4   | 8.0 | 90  |      |       | Y   |
| 5   | 8.0 | 80  |      |       | Y   |
| 6   | 8.0 | 80  |      |       | Y   |
| 7   | 7.8 | 80  |      |       | Y   |
| 8   | 7.8 | 80  |      |       | Y   |
| 9   | 8.0 | 80  |      |       | Y   |
| 10  | 8.0 | 85  |      |       | Y   |
| 11  | 8.0 | 90  |      |       | Y   |
| 12  | 8.0 | 95  |      |       | Y   |
| 13  | 8.0 | 87  |      |       | Y   |
| 14  | 8.0 | 90  |      |       | Y   |
| 15  | 8.1 | 82  |      |       | Y   |
| 16  | 7.6 | 82  |      |       | Y   |
| 17  | 7.3 | 56  |      |       | Y   |
| 18  | 7.5 | 76  |      |       | Y   |
| 19  | 7.3 | 68  |      |       | Y   |
| 20  | 7.6 | 81  |      |       | Y   |
| 21  | 7.6 | 80  |      |       | Y   |
| 22  | 8.0 | 83  |      |       | Y   |
| 23  | 7.9 | 75  |      |       | Y   |
| 24  | 7.3 | 58  |      |       | Y   |
| 25  | 7.3 | 62  |      |       | Y   |
| 26  | 7.3 | 75  |      |       | Y   |
| 27  | 7.5 | 80  |      |       | Y   |
| 28  | 7.9 | 82  |      |       | Y   |
| 29  | 7.9 | 82  |      |       | Y   |
| 30  | 8.2 | 91  |      |       | Y   |
| 31  | 8.2 | 100 |      |       | Y   |
|     |     |     |      |       | 0   |

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: October 2025  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

|       |     |                  |
|-------|-----|------------------|
| pH    | 7.2 |                  |
| Alk   | 20  | (Alkalinity)     |
| PO4   | N/A | (Orthophosphate) |
| Other | N/A | (_____)          |

Print Name: Alicia Olson

Signature: [Signature]

Date: 11/3/2025

Send to DWP within 10 days after end of sampling period