

Day	pH	Alk	Phos	Other	Y/N
1	7.6	82			Y
2	7.6	83			Y
3	7.6	98			Y
4	7.6	81			Y
5	7.6	85			Y
6	8.0	90			Y
7	8.0	90			X
8	8.0	100			Y
9	7.8	82			Y
10	7.8	97			Y
11	7.9	97			Y
12	8.1	94			Y
13	8.1	90			Y
14	8.2	84			Y
15	8.2	88			Y
16	8.1	82			Y
17	8.2	100			Y
18	8.1	94			Y
19	7.9	90			Y
20	8.1	96			Y
21	8.0	100			Y
22	8.0	86			Y
23	8.0	100			Y
24	8.0	100			Y
25	8.0	100			Y
26	7.8	92			Y
27	7.8	90			Y
28	7.8	90			Y
29	8.0	100			Y
30	7.9	108			Y
31	7.9	90			Y
					<u>0</u>

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: December 2025
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	20	(Alkalinity)
PO4	N/A	(Orthophosphate)
Other	N/A	(_____)

Print Name: Alicia Olson

Signature: [Signature]

Date: 12/1/26 1/6/26

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0