

Day	pH	Alk	Phos	Other	Y/N
1	7.8	96			Y
2	7.8	80			Y
3	7.8	90			Y
4	7.6	104			Y
5	7.7	96			Y
6	7.7	84			Y
7	7.7	80			Y
8	7.7	80			Y
9	7.8	90			Y
10	7.6	84			Y
11	7.6	88			Y
12	8.0	90			Y
13	7.8	100			Y
14	7.8	88			Y
15	8.0	83			Y
16	8.0	82			Y
17	8.0	80			Y
18	7.9	80			Y
19	8.1	82			Y
20	7.9	98			Y
21	7.8	100			Y
22	7.9	96			Y
23	7.9	100			Y
24	7.9	82			Y
25	7.7	81			Y
26	7.7	90			Y
27	7.8	96			Y
28	7.8	81			Y
29	7.7	80			Y
30	8.0	85			Y
31	8.0	87			Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: January 2026
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk 20 (Alkalinity)

PO4 N/A (Orthophosphate)

Other N/A (_____)

Print Name: Alicia Olson

Signature: [Signature]

Date: 2/4/26

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0