

Day	pH	Alk	Phos	Other	Y/N
1	8.2	90			Y
2	8.2	90			Y
3	7.9	95			Y
4	7.9	96			Y
5	7.8	92			Y
6	8.0	87			Y
7	8.0	85			Y
8	8.0	80			Y
9	8.0	78			Y
10	8.0	82			Y
11	8.0	82			Y
12	8.0	80			Y
13	8.0	80			Y
14	7.5	80			Y
15	7.6	80			Y
16	7.8	78			Y
17	7.8	80			Y
18	7.8	80			Y
19	7.8	78			Y
20	7.6	76			Y
21	7.8	70			Y
22	7.8	80			Y
23	7.8	82			Y
24	8.0	80			Y
25	8.0	84			Y
26	8.0	80			Y
27	8.0	80			Y
28	8.0	80			Y
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: February / 2026
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	20	(Alkalinity)
PO4	N/A	(Orthophosphate)
Other	N/A	(_____)

Print Name: Alicia Olson

Signature: [Signature]

Date: 3/1/2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0