

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.0	80			Y
2	8.0	80			Y
3	7.8	78			Y
4	7.8	80			Y
5	7.8	82			Y
6	7.6	80			Y
7	7.6	80			Y
8	7.6	83			Y
9	7.6	81			Y
10	7.6	78			Y
11	7.5	80			Y
12	7.6	76			Y
13	7.5	75			Y
14	7.4	82			Y
15	7.4	80			Y
16	7.4	80			Y
17	7.4	78			Y
18	7.4	80			Y
19	7.5	81			Y
20	7.4	83			Y
21	7.5	72			Y
22	7.6	74			Y
23	7.6	76			Y
24	7.6	81			Y
25	7.5	82			Y
26	7.6	92			Y
27	7.6	78			Y
28	7.5	70			Y
29	7.5	100			Y
30	7.5	98			Y
31	7.5	86			Y
					<u>0</u>

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41-00886

System Name: Cloverdale Water District

Entry Point: A

Sample Period: March 2026
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	20	(Alkalinity)
PO4	N/A	(Orthophosphate)
Other	N/A	()

Print Name: Alicia Olson

Signature: [Signature]

Date: 4/2/2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's