

Day	pH	Alk	Phos	Sili	Y/N
31	7.42				Y
30	7.36				Y
29	7.63				Y
28	7.62				Y
27	7.58				Y
26	7.15				Y
25	7.78				Y
24	7.49				Y
23	7.47				Y
22	7.37				Y
21	7.64				Y
20	7.78				Y
19	7.87				Y
18	7.96				Y
17	7.82				Y
16	7.64				Y
15	7.74				Y
14	7.89				Y
13	7.99				Y
12	7.91				Y
11	7.7				Y
10	7.53				Y
9	7.65				Y
8	7.74				Y
7	7.79				Y
6	7.92				Y
5	7.99				Y
4	7.89				Y
3	7.69				Y
2	7.61				Y
1	7.59				Y

<<Have minimums been met for this day?

**ENTRY POINT
A**

PWS ID 4100886

CLOVERDALE WATER DISTRICT

Sample period: May 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
Is system in compliance? Y / N

Reference _____

**Minimum Water Quality
Parameters as set by State:**

pH 7.2

Print Name: Larry Whitwood
Signature: _____
Date: 5/6/21

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period
Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381