



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
31	7.5				Y
30	7.55				Y
29	7.56				Y
28	8.0				Y
27	8.04				Y
26	8.15				Y
25	8.1				Y
24	7.86				Y
23	7.88				Y
22	7.91				Y
21	7.4				Y
20	7.5				Y
19	7.43				Y
18	7.86				Y
17	7.78				Y
16	7.7				Y
15	7.69				Y
14	7.74				Y
13	7.77				Y
12	7.89				Y
11	7.92				Y
10	8.39				Y
9	8.35				Y
8	8.01				Y
7	7.93				Y
6	7.95				Y
5	7.66				Y
4	7.36				Y
3	7.45				Y
2	7.39				Y
1	7.22				Y

<<Have minimums been met for this day?

ENTRY POINT
A
PWS ID 4100886
CLOVERDALE WATER DISTRICT

Sample period: July/2022
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
 Is system in compliance? Y / N

Reference _____

Minimum Water Quality Parameters as set by State:
 pH 7.2

Print Name: Larry Chitwood
 Signature: [Signature]
 Date: 7-8-2022

(No = N = Excursion) Total N's 0