

Water Quality Parameter Form - ENTRY POINT A (EP-A)

**Lead & Copper Rule Corrosion Control**

PWS Name/ID: City of Tillamook Water Dept - 4100893

Sample Period: February 2021

Sample Frequency: At least every 2 weeks



Day	pH	Alk	Phos	Other	yes/no	Have minimums been met for this day?
1	8.41					
2	8.95					
3	8.44					
4	8.01					
5	7.82					
6	8.23					
7	7.82					
8	7.84					
9	7.85					
10	7.93					
11	7.87					
12	8.44					
13	7.86					
14	7.74					
15	7.77					
16	7.68					
17	7.70					
18	8.18					
19	7.81					
20	7.77					
21	7.84					
22	7.70					
23	8.78					
24	7.71					
25	7.72					
26	7.83					
27	7.81					
28	7.83					
29						
30						
31						

Total excursions during the previous five months: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. EP and Dist excursions are cumulative)

For OHA use only:	
Minimum Water Quality Parameters as set by OHA:	
pH	7.2
Alk	
PO4	
Other	

Total number of excursions for the month = \_\_\_\_\_

Send to [dwpmce@state.or.us](mailto:dwpmce@state.or.us) within 10 days after end of sampling period

Print Name: ) Levi Beachy

Signature: \_\_\_\_\_

Date & Phone #: 03/01/2021 503-812-8804