



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- A**

Day	pH	Alk	Phos	Sili	Y/N
1	7.64				Y
2	7.66				Y
3	7.71				Y
4	7.73				Y
5	7.70				Y
6	7.73				Y
7	7.70				Y
8	7.74	21			Y
9	8.08				Y
10	7.72				Y
11	7.72				Y
12	7.72				Y
13	7.93				Y
14	7.71	23			Y
15	7.72				Y
16	7.71				Y
17	7.71				Y
18	7.83				Y
19	7.73	21			Y
20	7.86				Y
21	7.73				Y
22	7.80				Y
23	8.07				Y
24	8.48				Y
25	8.13				Y
26	7.99				Y
27	8.14	23			Y
28	8.18				Y
29	8.59				Y
30	8.28				Y
31	8.32				Y

<< Have minimums been met for this day?

PWS ID: 41

0	0	8	9	3
---	---	---	---	---

System Name:

Tillamook Water Dept, City of

Sample Period

July 2021

Month/Year

Number of excursions\* during this month: 0

( Over 9 excursions in 6 months is a violation.

Entry Point and Distribution excursions are

Cumulative). An 'excursion' is any day in which the

water quality parameter(s) fall below the minimum

set by the State

**Minimum Water Quality**

**Parameters as set by State:**

pH	7.2	
Alk	20	(Alkalinity)

Print Name: Levi Beachy

Signature:

Date: August 5, 2021

(N=Excursion) Total N's 0

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>