



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- A**

Day	pH	Alk	Phos	Sili	Y/N
1	8.34				Y
2	8.33	24			Y
3	8.33				Y
4	8.34				Y
5	8.33				Y
6	8.66				Y
7	8.28				Y
8	8.28				Y
9	8.20				Y
10	8.22				Y
11	8.23	21			Y
12	8.29				Y
13	8.30				Y
14	8.32				Y
15	8.32				Y
16	8.37	28			Y
17	8.67				Y
18	8.42				Y
19	8.39				Y
20	8.33				Y
21	8.37				Y
22	8.37				Y
23	8.72				Y
24	8.37				Y
25	8.31	23			Y
26	8.33				Y
27	8.30				Y
28	8.36				Y
29	8.39				Y
30	8.47	20			Y
31	8.65				Y

<< Have minimums been met for this day?

PWS ID: 41

0	0	8	9	3
---	---	---	---	---

System Name:

Tillamook Water Dept, City of

Sample Period

August 2021

Month/Year

Number of excursions\* during this month: 0

( Over 9 excursions in 6 months is a violation.

Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

**Minimum Water Quality Parameters as set by State:**

pH	7.2	
Alk	20	(Alkalinity)

Print Name:

Levi Beachy

Signature:

Date:

September 1, 2021

(N=Excursion) Total N's

0

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>