



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- A**

Day	pH	Alk	Phos	Sili	Y/N
1	7.75	23			Y
2	7.70				Y
3	7.68				Y
4	7.60				Y
5	8.70				Y
6	7.62				Y
7	7.61				Y
8	7.57	29			Y
9	7.64				Y
10	7.57				Y
11	7.56				Y
12	7.56				Y
13	7.56				Y
14	7.43				Y
15	7.41	25			Y
16	7.70				Y
17	7.58				Y
18	7.59				Y
19	7.68				Y
20	7.60				Y
21	7.67				Y
22	7.67				Y
23	8.04	24			Y
24	7.62				Y
25	7.76				Y
26	7.61				Y
27	7.97				Y
28	8.00				Y
29	7.50				Y
30	7.47	20			Y
31					Y

<< Have minimums been met for this day?

PWS ID: 41

**System Name:** Tillamook Water Dept, City of

**Sample Period:** November 2021  
Month/Year

**Number of excursions\* during this month:** 0  
( Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

**Minimum Water Quality Parameters as set by State:**

pH	<input type="text" value="7.2"/>	
Alk	<input type="text" value="20"/>	(Alkalinity)
	<input type="text"/>	

**Print Name:** Levi Beachy

**Signature:**

**Date:** December 1, 2021

(N=Excursion) **Total N's**

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>