



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- A

Day	pH	Alk	Phos	Sili	Y/N
1	8.20				Y
2	7.91	30			Y
3	7.85				Y
4	7.87				Y
5	8.07				Y
6	8.00				Y
7	7.86	28			Y
8	7.90				Y
9	8.20				Y
10	7.85				Y
11	7.90				Y
12	7.89				Y
13	7.91				Y
14	8.05				Y
15	7.85				Y
16	7.88	22			Y
17	8.10				Y
18	7.90				Y
19	7.91				Y
20	7.92				Y
21	8.33				Y
22	8.14	25			Y
23	7.91				Y
24	7.91				Y
25	7.94				Y
26	7.93				Y
27	7.94				Y
28	8.10				Y
29					Y
30					Y
31					Y

<< Have
minimums
been met
for this day?

PWS ID: 41

System Name: Tillamook Water Dept, City of

Sample Period February 2022
Month/Year

Number of excursions* during this month: 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
Cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State

**Minimum Water Quality
Parameters as set by State:**

pH
Alk (Alkalinity)

Print Name: Levi Beachy

Signature:

Date: March 9, 2022

=N=Excursion) Total N's

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>