



Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- A**

Day	pH	Alk	Phos	Sili	Y/N
1	8.14				Y
2	7.60	20			Y
3	7.76				Y
4	8.13				Y
5	7.78				Y
6	7.84				Y
7	7.88	24			Y
8	7.88				Y
9	8.22				Y
10	7.92				Y
11	7.92				Y
12	7.91				Y
13	7.99				Y
14	8.35				Y
15	7.82				Y
16	7.84				Y
17	7.85	26			Y
18	7.85				Y
19	7.90				Y
20	7.87				Y
21	7.97				Y
22	7.66	25			Y
23	7.92				Y
24	8.01				Y
25	8.43				Y
26	7.96				Y
27	8.00				Y
28	7.95				Y
29	8.53				Y
30	8.00	21			Y
31	8.09				Y

<< Have minimums been met for this day?

PWS ID: 41

**System Name:** Tillamook Water Dept, City of

**Sample Period** March 2022  
Month/Year

**Number of excursions\* during this month:** 0  
( Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State

**Minimum Water Quality Parameters as set by State:**

pH   
Alk  (Alkalinity)

**Print Name:** Levi Beachy

**Signature:**

**Date:** April 5, 2022

=N=Excursion) **Total N's**

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>