Oregon Health Authority

Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- A**

| Day | pH | Alk | Phos | Sili | Y/N |
|---|---|---|---|---|---|
| 1 | 7.91 | | | | Y |
| 2 | 8.02 | | | | Y |
| 3 | 7.99 | 21 | | | Y |
| 4 | 8.03 | | | | Y |
| 5 | 8.46 | | | | Y |
| 6 | 7.99 | | | | Y |
| 7 | 8.59 | | | | Y |
| 8 | 8.24 | | | | Y |
| 9 | 7.96 | | | | Y |
| 10 | 8.19 | | | | Y |
| 11 | 7.95 | | | | Y |
| 12 | 8.10 | | | | Y |
| 13 | 7.94 | | | | Y |
| 14 | 7.76 | | | | Y |
| 15 | 7.31 | | | | Y |
| 16 | 7.87 | 23 | | | Y |
| 17 | 7.98 | | | | Y |
| 18 | 7.94 | | | | Y |
| 19 | 7.93 | | | | Y |
| 20 | 8.22 | | | | Y |
| 21 | 7.95 | | | | Y |
| 22 | 7.96 | | | | Y |
| 23 | 7.93 | 21 | | | Y |
| 24 | 7.98 | | | | Y |
| 25 | 8.40 | | | | Y |
| 26 | 7.93 | | | | Y |
| 27 | 7.98 | | | | Y |
| 28 | 7.96 | | | | Y |
| 29 | 8.14 | | | | Y |
| 30 | 7.93 | | | | Y |
| 31 | 8.03 | 22 | | | Y |
| =N=Excursion) **Total N's** | | | | | 0 |

<< Have minimums been met for this day?

**PWS ID: 41** 0 0 8 9 3

**System Name:** Tillamook Water Dept, City of

**Sample Period** May 2022

Month/Year

**Number of excursions* during this month:** 0

*( Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are* Cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum *set by the State*

**Minimum Water Quality Parameters as set by State:**

pH 7.2

Alk 20 *(Alkalinity)*

**Print Name:** Levi Beachy

**Signature:**

**Date:** June 9, 2022

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: http://healthoregon.org/dwp/