



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

County: Tillamook

Agency: Region 1

**ENTRY POINT**

**EP- A**

Day	pH	Alk	Phos	Sili	Y/N	<< Have minimums been met for this day?	PWS ID: 41	<input type="text" value="0"/> <input type="text" value="0"/> <input type="text" value="8"/> <input type="text" value="9"/> <input type="text" value="3"/>						
1	8.40				Y									
2	7.98				Y									
3	7.92				Y									
4	8.06				Y		<b>System Name:</b>	Tillamook Water Dept, City of						
5	8.35				Y									
6	7.94	21			Y		<b>Sample Period</b>	June 2022						
7	8.00				Y			Month/Year						
8	7.91				Y									
9	8.01				Y									
10	8.12				Y		<b>Number of excursions* during this month:</b>	0						
11	7.81				Y		<i>( Over 9 excursions in 6 months is a violation.</i>							
12	8.42				Y		<i>Entry Point and Distribution excursions are</i>							
13	8.00				Y		<i>Cumulative). An 'excursion' is any day in which the</i>							
14	7.94				Y		<i>water quality parameter(s) fall below the minimum</i>							
15	7.94				Y		<i>set by the State</i>							
16	7.94				Y									
17	8.21				Y									
18	7.95				Y									
19	7.96				Y									
20	7.88	20			Y									
21	7.89				Y									
22	7.83				Y									
23	7.96				Y									
24	8.30				Y									
25	7.91				Y									
26	8.44				Y									
27	7.96				Y									
28	8.31				Y									
29	7.92	23			Y									
30	8.36				Y		<b>Print Name:</b>	Levi Beachy						
31					Y		<b>Signature:</b>							
=N=Excursion) Total N's							<b>Date:</b>	July 5, 2022						

**System Name:** Tillamook Water Dept, City of

**Sample Period** June 2022  
Month/Year

**Number of excursions\* during this month:** 0  
*( Over 9 excursions in 6 months is a violation.*  
*Entry Point and Distribution excursions are*  
*Cumulative). An 'excursion' is any day in which the*  
*water quality parameter(s) fall below the minimum*  
*set by the State*

<b>Minimum Water Quality Parameters as set by State:</b>		
pH	<input type="text" value="7.2"/>	
Alk	<input type="text" value="20"/>	(Alkalinity)
	<input type="text"/>	

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>