



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

County: Tillamook

Agency: Region 1

ENTRY POINT

EP- A

Day	pH	Alk	Phos	Sili	Y/N
1	8.22				Y
2	7.91				Y
3	7.96				Y
4	7.94				Y
5	8.04				Y
6	8.19				Y
7	8.16				Y
8	7.94				Y
9	7.96				Y
10	7.90	29			Y
11	8.04				Y
12	7.92				Y
13	7.88				Y
14	7.90				Y
15	7.87	27			Y
16	8.25				Y
17	8.29				Y
18	7.90				Y
19	7.90				Y
20	8.29				Y
21	7.88				Y
22	7.88	27			Y
23	7.88				Y
24	8.42				Y
25	7.97				Y
26	7.98				Y
27	7.97				Y
28	8.03				Y
29	8.01				Y
30	7.92	29			Y
31	7.97				Y

<< Have
minimums
been met
for this day?

PWS ID: 41

System Name: Tillamook Water Dept, City of


Sample Period August 2022
Month/Year

Number of excursions* during this month: 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
Cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State

**Minimum Water Quality
Parameters as set by State:**

pH

Alk (Alkalinity)

Print Name: Levi, Beachy
Signature: 
Date: September 1, 2022

=N=Excursion) **Total N's**

Send to DHS within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>